
OVERHEAD SERVICE

4.05.1



NOTE:

FOR CLEARANCE, SEE SECTION 7.01

IDENTIFY METER WITH SPACE OR APARTMENT NUMBER

SCHEDULE 80 PVC EMT OR RIGID CONDUIT WILL BE ALLOWED OUTSIDE ON ANY COMMERCIAL OR MULTI-POSITION RESIDENTIAL METER PROJECTS