

CUSTOMER INSTALLED PULLBOX

MAXIMUM 1/0 CABLE DO NOT INSTALL IN DRIVING SURFACE

SINGLE PHASE: 8.08.7A THREE PHASE: 8.08.7B





DIMENSIONS			CONDUIT	EXCAVATION	MAX CABLE	MAX NO OF
STD		Y	KNOCKOUTS	REQ'D (LABOR)	SIZE	SPLICES
8.08.7A	60"	36"	4 3/4"	7 CU YDS	1/0	2
8.08.7B	78"	48"	4 3/4"	9.8 CU YDS	1/0	6

NOTE:

- 1 DESIGN LOAD HS-20-44 (FULL TRAFFIC LOADING).
- 2 CDR (DIVISION OF HOMAC MFG CO).
- 3 PLACEMENT PER MANUFACTURER'S RECOMMENDATION.
- 4 PULLBOX IS FOR OPPD'S EXCLUSIVE USE. JOINT USE WITH CUSTOMER EQUIPMENT OF ANY NATURE SHALL NOT BE ALLOWED.

Revised 09-15-08 By SAH DESIGN ENTRY BY: BRANT DANGEL

ISSUED DATE