

SD-4: Reliability Monitoring Report

System Management & Nuclear Oversight Committee Report

Troy Via COO & VP Utility Operations



Summary SD-4: Reliability

As our communities become more reliant on electric services, the reliability of that service must also continue to improve. The Generation Fleet, Transmission System, and Distribution System are all elements of OPPD's vertically integrated systems to delivery energy services to our customer-owners. The reliability of each of these system elements contributes to the overall reliability of our service.

Therefore, to demonstrate reliable operations of its electric utility system, OPPD shall:

• Assure all customer energy requirements are met through the use of its generation resources and purchased power portfolio 100 percent of the time; and

Generation

 Maintain OPPD's owned generation fleet Equivalent Forced Outage Rate (EFOR*) at or below the middle of the second quartile of a benchmark fleet of comparable generation; and

Transmission

• Operate and maintain the system in accordance with all applicable NERC Reliability Standards; and

Distribution

- Maintain the System Average Interruption Duration Index (SAIDI*) to top quartile performance for a benchmark of comparable electrical utilities, excluding Major Event Days; and
- Maintain the System Average Interruption Frequency Index (SAIFI*) to top quartile performance for a benchmark of comparable electric utilities, excluding Major Event Days.

All measures will be tracked on a 12-month rolling average basis.




2023 Performance

SD-4 Performance

- Met customer energy requirements 100% of the time
- X Improvement needed to reduce forced generation outages
- Minimized duration of outages for customers
- Minimized frequency of outages for customers
- Met applicable NERC reliability standards




OPPD shall assure generation resources and purchase power portfolio meets customer energy demand 100% of the time.



Energy Supply

OPPD has met supply requirements in a challenging environment that includes weather events, increased demand and increasing capacity requirements that ensure system reliability.


- $\checkmark\,$ SPP real-time balancing of generation and load
- ✓ SPP 115% planning reserve margin (Summer/Winter)
- Transmission reservations under SPP tariff provide a firm "lane in the highway" to deliver energy to load





Generation Reliability








Equivalent Availability Factor (EAF): Previous Metric

Percentage of time generation was available




2023 EAF 3 year was 81.7%, 3rd Quartile Performance

* Coal Stations Only



Equivalent Forced Outage Rate (EFOR):

Ratio of Forced Outage Hours to Service Hours



2023 EFOR was 16.1%, 3rd Quartile Performance

*Includes all owned generation



Improving Generation Reliability









Predictive, pro-active planning

Front-line engagement to identify and fix problems -Generation Reliability Improvement Program Comprehensive equipment review based on industry standards SD-4 metric that allows us to take more time in planned outages to address issues

Comprehensive approach designed to help OPPD identify and address more reliability risks quickly



Electric System Reliability



System Average Interruption Duration Index (SAIDI):

Average outage length across the system per customer




2023 SAIDI <u>58 Minutes</u>, 1st Quartile Performance



System Average Interruption Frequency Index (SAIFI):

Average frequency of outages across the system




2022 SAIFI 0.45 incidents, 1st Quartile Performance



Record: Underground Cable

Ongoing investment in underground cable program has yielded a definite return: 2023 had the lowest recorded cable failures on record








Maintain a reliable transmission system in accordance with NERC standards



Transmission reliability

OPPD has met all regulatory requirements to ensure a reliable transmission system.

- ✓ MRO 2023 audits
 - Off-site (quarterly) → no enforceable violations
 - On-site (every 3-years, 2025) → no enforceable violations
- ✓ OPPD performs continuous monitoring
- ✓ No enforceable NERC violations since the last SD-4 update





Recommendation:

The System Management & Nuclear Oversight Committee has reviewed and accepted this Monitoring Report for SD-4 and recommends that the Board finds OPPD is taking reasonable and appropriate measures to comply with Board Policy SD-4.

SD-4 Performance

- Met customer energy requirements 100% of the time
- Improvement needed to reduce forced generation outages
- Minimized duration of outages for customers
- Minimized frequency of outages for customers
- Met applicable NERC reliability standards

Х



Any reflections on

what has been accomplished, challenges and/or strategic implications?

