



Revised November 3, 2011

HP System may be wired unrestricted or through a dual-fuel thermostat, if using an outdoor thermostat see list below.
THIS LIST IS IN ALPHABETICAL ORDER. IT IS NOT BASED ON PRICE, PERFORMANCE OR QUALITY.

List of acceptable tested thermostats (only applies to add-on Heat Pumps):

- AprilAire – all 8400 series stats
- AprilAire 8570 & 8600
- American Standard 402, 803 and ACONT900
- Braeburn 3200,5200, 5300 & 5400
- C3 Climatouch
- Carrier/Bryant Dual-Fuel – TSTATCCPDF01-B
- Carrier Infinity
- Carrier/Bryant Performance Series TP-PRH & T6-PRH
- Carrier/Bryant Thermidistat – TSTATCCPRH01-B
- Coleman EVCON Multistage
- EWC Zone control model UZC4 & BMPlus300 only when OAS sensor is installed and dip switch R-33 is set to OAS position
- Fast HVACR TS21 Touchscreen TRMST
- Goodman Multi-Stage HPT-18-60
- Honeywell all wireless models and kits are acceptable provided the set points are set for demand change-over with fossil fuel.
- Honeywell 4210D,5000 & 6000 series thermostats
- Honeywell Prestige® IAQ 2.0 Comfort Systems thermostats
- Honeywell TZ4 Zone Control
- Honeywell HZ 432 Zone control with ODAS or Installer set-up: Stage 2 control = stat, For Vision Pro 8320 while using this board options must be 170 = 12 (heat pump 3h/2c), 190= 0 (change over “0”), 200= 0 (auxiliary heat electric)
- Honeywell Prestige IAQ
- Honeywell VisionPro 8000 set in dual-fuel mode and 20 outdoor temperature setting
- Honeywell VisionPro IAQ th9421
- Lennox Comfort Sense 7000 series – **Stage delay timer off** and differential set at .5 or greater
- Lennox Elite Programmable Touch Screen Thermostat
- Lennox SignatureStat (must be programmed with the balance point set at 20F and the switchover temperature set at 21F along with the timer being set at 40 minutes)
- Lux Models PSPU721T, PSPU732T – with Aux Indicator Setting at OFF only
- Pro 1 T955W master thermostat (with sensor) wireless
- Pro 1 IAQ Thermostats (models 725, 755, 855, 915 and 925)
- Rheem model # RHC-TSTS305UNMS
- RUUD / RHEEM UHC-TST-401MDMS Programmable (with outdoor sensor) or 1F-85-277w/BPods
- Talking Thermostat VT 2005
- Trane 402, 803, TCONT 900, and XL 950
- White-Rodgers 1F72-151 Heat Pump Programmable
- White-Rodgers 1F79-111 Heat Pump Non-Programmable
- White-Rodgers 1F79-211 Heat Pump Non-Programmable
- White-Rodgers 1F95-391 Multi-Stage Programmable
- White-Rodgers 1F95- all models
- White-Rodgers CTK01 Communicating thermostat
- ZONEX Systems DTPH4A zone control board with integrated fossil fuel control

List of acceptable Outdoor Thermostats:

- Bill Porter
- Johnson Controls – A350 with differential set at no higher than 3 degrees
- Ranco – ETC 112000 with differential set at no higher than 3 degrees

Note:

Mechanical outdoor thermostats are not acceptable; this includes thermal disc type, bulb type and bimetal strip type. Only electronic outdoor thermostats are acceptable. Indoor thermostats with outdoor sensors can be used. Indoor thermostats with timers that automatically switch from first to second stage are not acceptable.

If you have any questions, please contact Jeni Hoffman at 402-636-3524, or email jkhoffman@oppd.com.