

CONTENTS BY CHAPTER

Chapter 1: GENERAL INFORMATION

Chapter 2: COMPANY EQUIPMENT ON CUSTOMER PREMISES

Chapter 3: SERVICE ENTRANCES

Chapter 4: METERING INSTALLATION

Chapter 5: CUSTOMER-INSTALLED SERVICE POLE

Section 5.01-5.07: OVERHEAD TEMPORARY SERVICE POLE

Section 5.51-5.56: UNDERGROUND TEMPORARY SERVICE POLE

Chapter 6: OVERHEAD SERVICES

Chapter 7: UNDERGROUND SERVICES (RESIDENTIAL)

**Chapter 8: UNDERGROUND SERVICES (GENERAL SERVICE &
MULTI-UNIT RESIDENTIAL)**

Chapter 9: MOBILE HOME SERVICES

Chapter 10: SERVICE IMPAIRING EQUIPMENT REGULATIONS

Chapter 11: CUSTOMER'S STANDBY GENERATION INSTALLATIONS

Chapter 12: NETWORK SERVICES

See following pages for more content detail.

TABLE OF CONTENTS

SECTION Chapter 1: GENERAL INFORMATION

- 1.01 PURPOSE
- 1.02 CONSULT WITH OPPD
 - PHONE NUMBERS
- 1.03 GENERAL POLICY
- 1.04 CODES AND RULES
- 1.05 INSPECTIONS
- 1.06 CONTINUITY OF SERVICE
- 1.07 FREQUENCY AND SERVICE OPTIONS AVAILABLE
 - SINGLE PHASE
 - THREE PHASE, WYE
 - THREE PHASE, DELTA, 3W
 - THREE PHASE, DELTA, 4W
 - OTHER SERVICES:
 - PULSE METERING
 - 6W TOTALIZED (NOT FOR NEW CONSTRUCTION)
 - 5W TOTALIZED (SERVICE ELIMINATED; NOT FOR NEW CONSTRUCTION)
- 1.08 HIGHER VOLTAGES
- 1.09 LOAD ADDITIONS
- 1.10 SERVICE CONNECTIONS
- 1.11 CUSTOMER ATTACHMENTS PROHIBITED
- 1.12 RESALE OF ENERGY
- 1.13 SALE OF OPPD PROPERTY
- 1.14 DIGGERS HOTLINE
- 1.15 OPENING A NEW SERVICE ACCOUNT

Chapter 2: COMPANY EQUIPMENT ON CUSTOMER PREMISES

- 2.01 GENERAL
- 2.02 ACCESS TO COMPANY EQUIPMENT

- 2.03 TAMPERING WITH METERS
- 2.04 TEMPORARY METERING ARRANGEMENTS
- 2.05 COORDINATION OF OPPD WORK WITH THE CUSTOMER

Chapter 3: SERVICE ENTRANCES

- 3.01 POINT OF ENTRANCE
 - GENERAL SERVICE
 - RESIDENTIAL
- 3.02 OPPD INSTALLATION
 - ACCESSIBLE METER LOCATION
 - DEFINITIONS
 - ONE BUILDING, ONE SERVICE
- 3.03 CUSTOMER INSTALLATION
 - OVERHEAD – RESIDENTIAL OR GENERAL SERVICE
 - UNDERGROUND - RESIDENTIAL
 - UNDERGROUND - GENERAL SERVICE
 - DISCONNECT SEQUENCE
- 3.04 CAPACITY
- 3.05 IDENTIFICATION OF CONDUCTORS
- 3.06 FAULT CURRENT DUTY REQUIREMENT
 - ONE AND TWO FAMILY DWELLINGS
 - MULTI-PHASE AND RESIDENTIAL, OTHER THAN ONE-, TWO- OR THREE-FAMILY DWELLINGS
- 3.07 PHASE BALANCE REQUIREMENTS
- 3.08 LIGHTS-ON-POWER SERVICE
- 3.09 SERVICE IMPAIRMENT
- 3.10 GROUNDING OF METER ENCLOSURE
 - SINGLE SOCKET METERING
 - MULTIPLE SOCKET, METER CENTERS, AND INSTRUMENT METERING

Chapter 4: METERING INSTALLATION

- 4.01 METERING SPECIFICATIONS
METERING EQUIPMENT PICK-UP

- GENERAL SERVICE, THREE PHASE
 - GENERAL SERVICE, SINGLE PHASE
 - RESIDENTIAL
- 4.02 CUSTOMER INSTALLATION – METER SOCKETS
- SOCKET METERING DRAWINGS & DIMENSIONS
- 4.03 RESIDENTIAL SERVICE
- OVERHEAD SINGLE FAMILY, DUPLEX, OR THREE-PLEX DWELLINGS
 - UNDERGROUND SINGLE FAMILY, DUPLEX, OR THREE-PLEX DWELLINGS
- 4.04 RESIDENTIAL/COMMERCIAL SERVICE - MULTIPLE OCCUPANCY
- RESIDENTIAL – 4 DWELLING UNITS OR MORE
 - COMMERCIAL – 2 OR MORE UNITS
- 4.05 GROUPING OF METERS
- METER CENTERS
- 4.06 CUSTOMER INSTALLATION - GENERAL SERVICE METERING INSTRUMENT TRANSFORMERS
- INSTRUMENT TRANSFORMERS DRAWINGS
 - CT CABINET
 - CABINET MOUNTING
 - MANUFACTURED SWITCHGEAR
 - SIX MAIN RULE
 - WIRING FOR INSTRUMENT TRANSFORMERS
- 4.07 CONNECTIONS
- SERVICE RISERS
- 4.08 METER LOCATIONS
- 4.09 MOUNTING
- UNDERGROUND, GENERAL SERVICE & ALL OVERHEAD
 - UNDERGROUND, RESIDENTIAL
- 4.10 METER SEALS
- 4.11 CAPACITY
- 4.12 SEPARATION
- 4.13 IDENTIFICATION OF METERS BY LOCATION
- 4.14 METER JUMPERS

4.15 HIGH VOLTAGE METERING

4.16 BONDING METERING ENCLOSURES

Chapter 5: CUSTOMER-INSTALLED SERVICE POLE

SECTION 5.01- 5.07: OVERHEAD TEMPORARY SERVICE POLE

5.01 GENERAL

5.02 SERVICE ENTRANCE CONDUCTORS

5.03 ATTACHMENT OF SERVICE DROPS

5.04 CONNECTIONS

5.05 CAPACITY

5.06 IDENTIFICATION OF CONDUCTORS

5.07 SERVICE POLE INSTALLATION

SECTION 5.51- 5.55: UNDERGROUND TEMPORARY SERVICE POLE

5.51 GENERAL

5.52 SERVICE ENTRANCE CONDUCTORS AND CONDUIT

5.53 WIRING

5.54 CAPACITY

5.55 SERVICE POLE INSTALLATION

Chapter 6: OVERHEAD SERVICES

6.01 GENERAL

- ATTACHMENT MAINTENANCE OF METER LOOPS
- CLEARANCES OVER POOLS
- OTHER CLEARANCES
- ACCESSIBLE OVERHEAD POINT OF ATTACHMENT

6.02 SERVICE ENTRANCE CONDUCTORS

- CONDUIT RISER
- WIRES OUT OF WEATHERHEAD

6.03 ATTACHMENT OF SERVICE DROPS - RESIDENTIAL

- RESIDENTIAL ATTACHMENT TYPES
 1. BOLT THROUGH VERTICAL EXTERIOR WALL

- 2. MAST-TYPE RISER
 - REWIRED RESIDENCES
 - METER-DISCONNECT COMBINATION ON AN EXISTING HOME WITH A NEW ADDITION
 - HEIGHT AND STRENGTH OF ATTACHMENT

- 6.04 CONNECTIONS
- 6.05 IDENTIFICATION OF CONDUCTORS
- 6.06 SEPARATION OF METERED AND UNMETERED CONDUCTORS
- 6.07 MAXIMUM SERVICE DROP LENGTH
- 6.08 SERVICE MAST INSTALLATION – RESIDENTIAL SOCKET
100-320 AMP – 120\240 VOLTS, SINGLE PHASE, 3 WIRE
- 6.09 WALL INSTALLATION – RESIDENTIAL SOCKET
FROM 100 TO 320 AMP – 120\240 VOLTS SINGLE PHASE, 3 WIRE
- 6.10 OVERHEAD RESIDENTIAL & GENERAL SERVICE CT INSTALLATION
- 6.11 FREE-STANDING SUPPORT FOR OVERHEAD SERVICE – BY CUSTOMER
- 6.12 GENERAL SERVICE 100 TO 320 AMP 1 PH SOCKET, MAST OR WALL INSTALLATION
- 6.13 GENERAL SERVICE 100 – 200 AMP 3 PH SOCKET, MAST OR WALL INSTALLATION
- 6.14 GENERAL SERVICE 320 AMP 3 PH 4W 120/208V OVERHEAD AND UNDERGROUND SOCKET

Chapter 7: UNDERGROUND SERVICES (RESIDENTIAL)

- 7.01 GENERAL
 - METERING ON PADMOUNTED TRANSFORMER
 - METER-DISCONNECT COMBINATION ON AN EXISTING HOME WITH A NEW ADDITION
- 7.02 SERVICE LATERAL REQUIREMENTS
 - CONDUIT INSTALLATION
 - EASEMENTS
 - GRADE CHANGES
 - RETAINING WALLS
- 7.03 CONNECTIONS

- 7.04 CLEARANCES
 - CANTILEVERS
 - BRICK LEDGE
- 7.05 UNDERGROUND SERVICE TO SINGLE OR DUPLEX METER SOCKET
SINGLE PHASE 100-320 AMPS, 240 VOLTS & UNDER
- 7.06 FREE-STANDING UNDERGROUND SERVICE ENTRANCE
100 THRU 200 AMPS, OR 320 AMP - 240 VOLTS & UNDER
- 7.07 UNDERGROUND SERVICE TO CT CABINET
SINGLE PHASE, 400 THRU 800 AMP - 120/240 VOLTS
- 7.08 REQUIREMENTS FOR PRIMARY & SECONDARY CABLES &
EQUIPMENT ON LARGE LOT RESIDENTIAL PRIVATE PROPERTY
(ACREAGES)
 - EASEMENT
 - GRADE CHANGES
 - RETAINING WALLS

**Chapter 8: UNDERGROUND SERVICES - GENERAL SERVICE AND
MULTI-UNIT RESIDENTIAL**

- 8.01 GENERAL
 - SERVICE RISER PIPES
- 8.02 CONNECTIONS
 - SECONDARY DIPS
 - PADMOUNTS
- 8.03 CLEARANCES
- 8.04 UNDERGROUND SERVICE TO METER SOCKET
- 8.05 FREE-STANDING SUPPORT FOR UNDERGROUND SERVICE ENTRANCE
- 8.06 UNDERGROUND SERVICE TO CT CABINET
- 8.07 UNDERGROUND SECONDARY SERVED FROM OVERHEAD
 - LIMITATIONS – DISTANCE
 - LIMITATIONS – SIZE
- 8.08 PADMOUNT TRANSFORMER SERVICE
 - PRIMARY DUCT & CONDUCTORS
 - TRANSFORMER SLAB
 - SINGLE PHASE
 - THREE PHASE, 500KVA & SMALLER
 - THREE PHASE, 750KVA & LARGER

- SLAB INSPECTION
- SECONDARY CONDUITS & CABLES
- METERING ON THE TRANSFORMER
- GENERAL PADMOUNTED TRANSFORMER REQUIREMENTS

- 8.09 THREE PHASE PADMOUNTED TRANSFORMER WITH SEPARATE SECONDARY COMPARTMENT
- ADDING ON TO AN EXISTING SLAB
 - SERVICE CONDUCTORS
 - INSTRUMENT TRANSFORMER METERING ON TRANSFORMER

Chapter 9: MOBILE HOME SERVICES

- 9.01 SCOPE
- 9.02 GENERAL
- 9.03 SINGLE CUSTOMER INSTALLATION - UNDERGROUND SERVICE
- 9.04 MOBILE HOME COURTS - UNDERGROUND SERVICE
- 9.06 MOBILE HOME UNDERGROUND PEDESTALS

Chapter 10: SERVICE IMPAIRING EQUIPMENT REGULATIONS

- 10.01 DEFINITION
- 10.02 STANDARDS OF PERFORMANCE
- 10.03 CUSTOMER RESPONSIBILITY
- 10.04 WELDERS AND FURNACES
- 10.05 RECTIFICATION PROCESSES

Chapter 11: CUSTOMER'S STANDBY GENERATION INSTALLATIONS

- 11.01 SCOPE
- NON-PARALLEL OPERATION (OPEN TRANSITION)
- 11.02 SAFETY
- 11.03 GENERATOR FREQUENCY AND VOLTAGE
- 11.04 CONNECTION
- 11.05 EMERGENCY STANDBY GENERATOR INSTALLATION

- 11.06 OPPD PROVIDED FARM DISCONNECT OR TRANSFER SERVICE
- 11.07 PARALLEL OPERATION

Chapter 12: NETWORK SERVICES – DOWNTOWN OMAHA AREA ONLY

- 12.01 GENERAL
- 12.02 SERVICE ENTRANCE CONDUCTORS
 - LUGS
- 12.03 TEMPORARY OR UNMETERED SERVICES
- 12.04 IDENTIFICATION OF CONDUCTORS
- 12.05 SEPARATION OF SERVICE CONDUCTORS FROM OTHER CONDUCTORS
- 12.06 REHAB OF EXISTING BUILDINGS

INDEX OF DRAWINGS:

Chapter 1

* indicates "NOT FOR NEW CONSTRUCTION"

- 1.07.1 SINGLE PHASE SOCKETS
- 1.07.2 SINGLE PHASE INSTRUMENT TRANSFORMERS (CT'S & PT'S)
- 1.07.3 THREE PHASE, 4 WIRE, WYE SOCKETS & CT'S
- 1.07.4 THREE PHASE, 3 WIRE, CLOSED DELTA SOCKETS
- 1.07.5 THREE PHASE, 3 WIRE, CLOSED DELTA (CT'S & PT'S)
- 1.07.6 THREE PHASE, 4 WIRE, CLOSED DELTA SOCKETS & CT'S
- 1.07.7 THREE PHASE, 3 WIRE, OPEN DELTA SOCKETS
- 1.07.8 THREE PHASE, 4 WIRE, OPEN DELTA SOCKETS & CT'S
- 1.07.9* 6 WIRE TOTALIZED SERVICE (NOT FOR NEW CONSTRUCTION)
- * 5 WIRE TOTALIZED SERVICE (NOT FOR NEW CONSTRUCTION)
- 1.07.10* 2 CKT TOTALIZED 3PH, 4W WYE (120/208V, 277/480V)
- 1.07.11* 2 CKT TOTALIZED 3PH, 4W DELTA (240V, 480V)
- 1.07.12 PRIMARY METERING SINGLE PHASE (480V, 2400V)
PRIMARY METERING 3 PH, 4W (13,800V)
- 1.07.13 PRIMARY METERING 3 PH, 3W (4160V)

Chapter 4

Socket Metering

- 4.02.1 120V 1PH 2W (1 KW MAXIMUM.)
- 4.02.2 120/240V 1PH 3W 150A OVERHEAD
- 4.02.3 120/240V 1PH 3W 200A OVERHEAD
- 4.02.4 120/240V 1PH 3W 200A UNDERGROUND
- 4.02.5 120/240V 1PH 3W 200A UNDERGROUND
- 4.02.6 120/240V 1PH 3W 320A OVERHEAD
- 4.02.7 120/240V 1PH 3W 320A UNDERGROUND
- 4.02.8* 240V 1PH 2W & 120/240V 1PH 3W TOTALIZED
- 4.02.9 240/480V 1PH 3W 200A OVERHEAD
- 4.02.10 240V 3PH 3W or 480V 3PH 3W 200A OVERHEAD
- 4.02.11* 480V 3PH 3W 200A OVERHEAD
- 4.02.12 120/240V 3PH 4W OVERHEAD
- 4.02.13 120/208V 3PH 4W or 277/480V 3PH 4W 200A OVERHEAD
- 4.02.14 120/208V 1PH 3W 150A OVERHEAD
- 4.02.15 120/208V 3PH 4W 320A OVERHEAD or UNDERGROUND

- 4.05.1 OVERHEAD SERVICE, 2 TO 6 METERS
- 4.05.2 UNDERGROUND SERVICE, 2 TO 6 METERS
- 4.05.3 UNDERGROUND SERVICE, 2 TO 6 METERS

Transformer Metering

- 4.06.1 DIAGRAM I, II, & III (6 MAIN RULE)
- 4.06.2* 120/240V 1PH 3W "A"-base CT

- 4.06.3 120/240V 1PH 3W socket CT
- 4.06.4* 120/240V 1PH 3W & 240V 3PH 3W 6W totalized "A"-base CT
- 4.06.5* 120/240V 1PH 3W & 240V 3PH 3W 6W totalized "A"-base CT kW
- 4.06.6* 120/240V 1PH 3W & 240V 3PH 3W 6W totalized "A"-base CT kW, kVA
- 4.06.7* 120/240V 1PH 3W & 240V 3PH 3W 6W totalized "A"-base CT kW
- 4.06.8* 240V 3PH 3W delta "A"-base CT
- 4.06.9* 3PH 3W delta Metering
- 4.06.10* 3PH 3W delta "A"-base CT (240V, 480V, 2400V, or 13,800V) kW, kVA
- 4.06.11* 3PH 3W delta socket CT (240V, 480V, 2400V, or 13,800V) kW, kVA
- 4.06.12* 3PH 3W delta "A"-base CT (480V, 2400V, or 13,800V) kW, kVA
- 4.06.13* 120/240/240V 3PH 4W "A"-base CT
- 4.06.14* 3PH 4W "A"-base CT (120/208V, 277/480V, 2400/4160V, or 7960/13,800V)
- 4.06.15 3PH 4W socket CT (120/208V, 277/480V, 2400/4160V, or 7960/13,800V)
- 4.06.16* 3PH 4W "A"-base CT (120/208V, 277/480V, 2400/4160V, or 7960/13,800V) kW, kVA
- 4.06.17* 3PH 4W socket CT (120/208V, 277/480V, 2400/4160V, or 7960/13,800V) kW, kVA
- 4.06.18* 3PH 4W "A"-base CT (120/208V, 277/480V, 2400/4160V, or 7960/13,800V) kW, kVA 2 circuit totalized
- 4.06.19 3PH 4W delta CT (120/240/240V)

Chapter 5

- 5.07.1 OVERHEAD TEMPORARY SERVICE POLE
- 5.07.2 OVERHEAD TEMPORARY SERVICE POLE
- 5.55 UNDERGROUND TEMPORARY SERVICE POST

Chapter 6

- 6.08.1 OVERHEAD RESIDENTIAL SERVICE: MAST INSTALLATION, SOCKET
- 6.08.3 OVERHEAD RESIDENTIAL SERVICE: THREE-PLEX SOCKET-200A.
- 6.09 OVERHEAD RESIDENTIAL SERVICE: WALL INSTALLATION, SOCKET
- 6.10 INSTRUMENT TRANSFORMER METERING RESIDENTIAL & GENERAL SERVICE OVERHEAD

Chapter 7

- 7.02.1 CUSTOMER-INSTALLED DUCT UNDER RETAINING WALL
- 7.02.2 DUCTED SERVICE REQUIREMENTS
- 7.04.1 UNDERGROUND RESIDENTIAL SOCKET ON A CANTILEVER
- 7.04.2 UNDERGROUND RESIDENTIAL SOCKET UNDER A CANTILEVER
- 7.05.1 UNDERGROUND RESIDENTIAL SERVICE: 200 AMP SOCKET
- 7.05.2 UNDERGROUND RESIDENTIAL SERVICE: 320 AMP SOCKET
- 7.05.3 UNDERGROUND RESIDENTIAL SERVICE: DUPLEX SOCKET
- 7.06 UNDERGRD RESIDENTIAL SVCE: FREESTANDING METER SUPPORT
- 7.07 UNDERGRD RESIDENTIAL SVCE: CURRENT TRANSFORMER (CT)

Chapter 8

- 8.04.1 UNDERGROUND SOCKET, GENERAL SERVICE: 200 AMP
- 8.04.2 UNDERGROUND SOCKET, GENERAL SERVICE: 320 AMP
- 8.05 UNDERGROUND SOCKET, GENERAL SERVICE: FREESTANDING
METER SUPPORT
- 8.06 UNDERGROUND, GENERAL SERVICE: INSTRUMENT
TRANSFORMER METER
- 8.08.1 SLAB DETAIL, 1PH PDMT TRANSFORMER. LOW PRO
(25 TO 167 kVA)
- 8.08.2 SLAB DETAIL, 1PH PDMT TRANSFORMER, CONV. (25 TO 167 kVA)
- 8.08.3 SLAB DETAIL, 1PH PDMT TRANSFORMER, CONV. (250 & 333 kVA)
- 8.08.4 SLAB DETAIL, 3PH PADMOUNTED TRANSFORMER, (75 TO 500 kVA)
- 8.08.5 SLAB DETAIL, 3PH PDMT TRANSFORMER, (750 TO 1000 kVA)
- 8.08.6 SLAB DETAIL, 3PH PDMT TRANSFORMER, (1500, 2000, &2500 kVA)
- 8.08.7 CUSTOMER'S CABLE PULL BOX INSTALLATION
- 8.08.8 METERING EQUIPMENT ON 3PH TRANSFORMER (AEOT)
- 8.08.9 6'x6' PRECAST MANHOLE
- 8.09.1 TRANSFORMER AND SECONDARY CAB SLAB (750, 1000 kVA)
- 8.09.2 TRANSFORMER AND SECONDARY CAB SLAB (1500, 2000, 2500 kVA)

Chapter 9

- 9.06.1 MOBILE HOME PARK SERVICE, UNDERGROUND, SINGLE METER
- 9.06.2 MOBILE HOME PARK SERVICE, UNDERGROUND, DOUBLE METER
- 9.07* MOBILE HOME PARK SERVICE, OVERHEAD POLE.

Chapter 11

- 11.08 DETENT METERING

Chapter 12

- 12.02.1 NETWORK CABLE LIMITER INSTALLATION, 208V.
- 12.02.2 NETWORK CABLE LIMITER INSTALLATION, 480V.