

20-EA-228

Memorandum

Date: November 25, 2020

Subject: Omaha Public Power District NC2 Ash Disposal Area Appendix IV exceedance, NDEE Permit Number NE 0204421, Facility Id 58343

On behalf of the Omaha Public Power District (OPPD) and in accordance with the U.S. Code of Federal Regulations, Title 40, Part 257.95(g), this letter serves as a notification that one or more constituents in Appendix IV are identified at Statistically Significant Level exceeding the Groundwater Protection Standard. The constituents for the NC2 Ash Disposal Area that exceed this standard are Arsenic and Lithium. OPPD is identifying if an alternative source demonstration will determine if Assessment of Corrective Measures is required. OPPD is planning to clean up releases from coal combustion residuals (CCR) pursuant to Title 40, Part 257.96, Assessment of Corrective Measures.

Pursuant to Title 40, Part 257.105(h)(8), "Within 30 days of detecting one or more constituents in appendix IV to this part at a statistically significant levels above the groundwater protection standard, the notification as required by 257.95(g)." this document will be placed in the operating record and satisfy this requirement.

Pursuant to Title 40 Part 257.106(h)(6), "Provide notification that one or more constituents in appendix IV to this part at statistically significant levels above the groundwater protection standard and notifications to land owners specified under 257.105(h)(8)." OPPD owns the land in and around the affected area and is hereby notified. The memo will be sent to the state director as required to fulfill this notification.

Pursuant to Title 40 Part 257.107(h)(6) "The notification that one or more constituents in appendix IV to this part have been detected at statistically significant levels above the groundwater protection standard and landowners specified under 257.105(h)(8). This document will be placed on the OPPD CCR internet site as required.