



# CCR Annual Fugitive Dust Control Report



Omaha Public Power District  
Nebraska City Station

*Nebraska City, Nebraska*  
December 15, 2021

# OPPD Nebraska City Station CCR Annual Fugitive Dust Control Report

## Table of Contents

1	Introduction .....	1
1.1	Purpose .....	1
1.2	Fugitive Dust Control .....	1
1.3	Citizen Complaints .....	2
1.4	Corrective Action Items .....	2

# 1 Introduction

On April 17, 2015, the U.S. Environmental Protection Agency (EPA) published the final rule for the regulation and management of coal combustion residuals (CCR) under subtitle D of the Resource Conservation and Recovery Act (RCRA). The CCR rule defines a set of requirements for the disposal and handling of CCR in landfills and surface impoundments. One of the operating criteria for air, 40 CFR §257.80(c), specifies that an owner or operator of a CCR landfill, surface impoundment, or lateral expansion of a CCR unit must complete an annual fugitive dust report.

## 1.1 Purpose

The CCR rule requires CCR landfills to develop a CCR fugitive dust control plan and adopt measures that will effectively minimize CCR from becoming airborne at the facility, including CCR fugitive dust originating from CCR units, roads, and other CCR management and material handling activities (40 CFR §257.80(a)). The plan must include:

- Identification of the CCR handling areas and control measures taken to minimize CCR fugitive dust at the facility
- Explanation of how dust control measures selected are applicable and appropriate for site conditions
- Emplacement of CCR in the landfill as conditioned CCR
- Procedures to log citizen complaints involving CCR fugitive dust events at the facility
- Description of procedures to periodically assess effectiveness of control plan

Additionally, an annual report must be developed to include any actions taken by the owner or operator to control fugitive dust, a record of all citizen complaints, and a summary of any corrective action measures taken. The initial annual report must be placed in the operating record no later than 14 months after placing the initial fugitive dust control plan into the operating record. All subsequent annual fugitive dust reports are required to be complete 1 year following the date of the previous report.

## 1.2 Fugitive Dust Control

The new ash contractor for OPPD has utilized the following dust control measures to minimize fugitive dust:

- Watering all areas of active equipment, haul roads, and active areas on the landfill
- Covering trailers after loading
- Ceasing operations on high wind days
- Good compaction of ash in active areas

Visual checks of the landfill are done daily to ensure fugitive dust is being controlled.

### 1.3 Citizen Complaints

OPPD's procedures to receive and log citizen complaints involving CCR fugitive dust events at the facility include the following:

- Citizens can complete an on-line form for complaints on CCR fugitive dust. The OPPD website ([www.oppd.com](http://www.oppd.com)) contains a link to the CCR Rule Compliance Data and Information website. A link to the on-line form is made available on the CCR website.
- When citizens submit the form, a designated OPPD person(s) will be notified.
- Appropriate personnel will investigate the complaint.
- Any corrective actions taken will be documented.
- A record of citizen complaints and responses will be maintained in the appropriate files.

OPPD did not receive any complaints related to fugitive dust in 2021.

### 1.4 Corrective Action Items

OPPD will conduct no corrective actions related to citizen complaints. OPPD is continuing to evaluate changes in the dust control plan due to a statistically significant level (SSL) above the established groundwater protection standard for lithium at a monitoring well down-gradient of the NC2 ash landfill. The SSL related to lithium was most likely due to windblown ash settling near the monitoring well and percolating down into the groundwater following precipitation events. OPPD has initiated an Assessment of Corrective Measures and is working toward a selection of remedy as required by 40 CFR Part 257, which may result in changes to the dust control plan.

OPPD has submitted a NC2 landfill permit change to the Nebraska Department of Environment and Energy (NDEE) that would allow use of an ash surface binder for controlling windblown dust on the landfill.